

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

Shelbyville Municipal Water & Sewer Commission Water Quality Report 2025

Water System ID: KY1060394

General Manager: Tom Doyle

502-633-2840

CCR Contact: Steve Searcy

Mailing address:

PO Box 608

Shelbyville, KY 40066

Public meeting location and time:

Water Office – 1059 Washington Street, Shelbyville, KY

3rd Monday each month at 6:30 PM

To request a paper copy of this report, call our office at (502) 633-2840.

Shelbyville Municipal Water & Sewer Commission utilizes surface water from Guist Creek Lake for your source of drinking water. Guist Creek Lake has a 29 square mile watershed which consists predominately of agricultural acreage, with some residential units around the lake. It is important that the community helps to protect this valuable water source located about 2.5 miles east of Shelbyville and north of US 60.

Activities and uses upstream of Guist Creek Lake can pose potential risks to your drinking water. Under certain circumstances, contaminants could be released that would pose challenges to water treatment, or even get into your drinking water. A source water assessment and protection plan has been completed for our watershed and is available for review in our offices during normal business hours. Some of the potential sources of contamination in our watershed consist of: four underground petroleum sites and one above-ground storage tank; two bridges; one inactive landfill and one site that uses hazardous materials (Bell South). These sources are rated as high in susceptibility to contamination because of their contaminant type, proximity to Guist Creek Lake, and high chance of release. Sources that are considered a medium risk for contamination of your water include major roads and commercial activities.

Water Purchased From Louisville

(Serves all customers with exception of Shelbyville area.)

Louisville Water operates two surface water treatment plants with intakes on the Ohio River. A Source Water Assessment and Protection Plan for Jefferson County identified spills of hazardous materials on the Ohio River and permitted discharges of sanitary sewers as the highest contamination risks. In Jefferson County, land use in the protection area is

primarily zoned for residential and commercial use, with only a few industrial sites. In Oldham and Trimble Counties (areas bordering the Ohio River to the north of our intakes) land use is primarily zoned for residential and agricultural use. Therefore source water contamination risks are relatively low. To view the entire Source Water Assessment and Protection Plan contact Keith Coombs at 502-569-3682. Louisville Water also draws water through the aquifer with riverbank filtration wells at the B.E. Payne Plant. The Kentucky Division of Water approved LWC's Wellhead Protection Plan (WHPP) in 2014. The goal is to safeguard groundwater feeding into the wells from contamination within the Wellhead Protection Area (WHPA) in Prospect. Louisville Water continually updates the plan. To view the entire Wellhead Protection Plan contact Kay Ball at 502-569-3688

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information About Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Service Line Inventory Information:

To address lead in drinking water, EPA requires that all community water systems develop and maintain an inventory of service line materials. We have completed a service line inventory (SLI) and it is available for review at 1059 Washington St., Shelbyville, KY 40066.

Lead Sample Results Availability Information:

We are required to periodically sample water from customer taps to determine lead and copper levels. EPA sets the lead action level at .015 mg/L (15 ppb). For a water system to be in compliance, at least 90% of tap water samples must have lead levels below this limit. This report contains the 90th percentile and range of our most recent sampling. The individual results for each location sampled can be reviewed at the water plant or by requesting a hard copy.

We are only required to test for some contaminants periodically, so the results listed in this report may not be from the previous year. Only detected contaminants are included in this report. For a list of all contaminants we test for please contact us. Copies of this report are available upon request by contacting our office.

Regulated Contaminant Test Results Shelbyville Water & Sewer Commission							
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Inorganic Contaminants							
Fluoride [1025] (ppm)	4	4	0.89	0.89 to 0.89	Mar-25	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	1.6	1.6 to 1.6	Mar-25	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Synthetic Organic Contaminants including Pesticides and Herbicides							
Atrazine [2050] (ppb)	3	3	0.88	0.4 to 1.8	May-25	No	Runoff from herbicide used on row crops
Disinfectants/Disinfection Byproducts and Precursors							
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.88 (lowest average)	1.00 to 2.98 (monthly ratios)	2025	No	Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.							
Chloramines (ppm)	MRDL = 4	MRDLG = 4	2.40 (highest average)	0.98 to 3.66	2025	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	40 (high site average)	6 to 54 (range of individual sites)	2025	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	37 (high site average)	12 to 46.8 (range of individual sites)	2025	No	Byproduct of drinking water disinfection.
Household Plumbing Contaminants							
Copper (ppm) Round 1 sites exceeding action level 1	AL = 1.3	1.3	1.004 (90 th percentile)	0.014 to 1.637	Aug-25	No	Corrosion of household plumbing systems
Lead (ppb) Round 1 sites exceeding action level 0	AL = 15	0	3 (90 th percentile)	0 to 8	Aug-25	No	Corrosion of household plumbing systems
Other Constituents							
Turbidity (NTU) TT * Representative samples	Allowable Levels		Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity	
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.09	100	No	Soil runoff	
Unregulated Contaminants (UCMR 5)			average	range (ppb)	date		
perfluoropentanoic acid (PFPeA)			0.001	0 to 0.0043	Jan. 2025		

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those that EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

Regulated Contaminant Test Results Louisville Water B. E. Payne Plant (B) Louisville Water Crescent Hill Plant (C)									
Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination	
Radioactive Contaminants									
Combined radium (pCi/L)	5	0	C=	BDL	BDL to 1.21	2025	No	Erosion of natural deposits	
Inorganic Contaminants									
Barium [1010] (ppm)	2	2	B=	0.016	0.016 to 0.016	2025	No	Drilling wastes; metal refineries; erosion of natural deposits	
			C=	0.021	0.021 to 0.021	2025	No		
Chromium [1020] (ppb)	100	100	B=	1.9	1.9 to 1.9	2025	No	Discharge from steel and pulp mills; erosion of natural deposits	
Fluoride [1025] (ppm)	4	4	B=	0.69	0.69 to 0.69	2025	No	Water additive which promotes strong teeth	
			C=	0.62	0.62 to 0.62	2025	No		
Nitrate [1040] (ppm)	10	10	B=	0.5	0 to 0.5	2025	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits	
			C=	0.96	0.63 to 0.96	2025	No		
Nitrite [1041] (ppm)	1	1	C=	0.014	0 to 0.014	2025	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits	
Disinfectants/Disinfection Byproducts and Precursors									
Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	C=	1.48	0.86 to 2.02	2025	No	Naturally present in environment.	
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.									
Other Constituents									
Turbidity (NTU) TT * Representative samples	Allowable Levels		Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity		
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% monthly samples		B= C=	0.08 0.10	100 100	2025 2025	Soil runoff		